



Compliance Certificate

Project Information

Project Title:	National Church Residences - St. Theresa Village
Energy Code:	2021 IECC
Location:	Cincinnati, Ohio
Construction Type:	Multi-family
Project Type:	Alteration
Project Sub Type:	None
Orientation:	Bldg. faces 45 deg. from North
Climate Zone:	4a (4988 HDD)
Project No:	1819990
All Electric:	false
Is Renewable:	false
Has Battery:	false
Has Charger:	false
Has Heat Pump:	false

Construction Site:
6783 Siebern Ave.
Cincinnati, OH 45236

Owner/Agent:
2245 N Bank Dr.
National Church Residences
Columbus, OH 43220

Designer/Contractor:
1398 Goodale Blvd.
Berardi + Partners
Columbus, OH 43212

Project Notes:

Envelope Assemblies

Assembly	Gross Area or Perimeter	Cavity R-Value	Cont. R-Value	Prop. U-Factor/ F-Factor	Req. U-Factor/ F-Factor	Prop. UA	Req. UA
Roof: Raised or Energy Truss	14520	49.0	0.0	0.020	0.024	290	348
Wall: Wood Frame, 16" o.c. Orientation: Unspecified Exemption: Framing cavity not exposed.	---	---	---	---	---	---	---
Window: Vinyl Frame SHGC: 0.3 Orientation: Unspecified	2500			0.270	0.300	675	750
Door: Solid Door (under 50% glazing) Orientation: Unspecified	44			0.170	0.300	8	13
Glazed Doors: Glass Door (over 50% glazing) SHGC: 0.4 Orientation: Unspecified	233			0.300	0.300	70	70

Compliance: Passes using prescriptive requirements for alteration projects


The % Better or Worse Than Code Index reflects how close to compliance the house is based on code trade-off rules. It DOES NOT provide an estimate of energy use or cost relative to a minimum-code home.

Slab-on-grade tradeoffs are no longer considered in the UA or performance compliance path in REScheck. Each slab-on-grade assembly in the specified climate zone must meet the minimum energy code insulation R-value and depth requirements.

Compliance Statement

The proposed building design described here is consistent with the building plans, specifications, and other calculations submitted with the permit application. The proposed building has been designed to meet the 2021 IECC requirements in REScheck-Web and to comply with the mandatory requirements listed in the REScheck Inspection Checklist.

Carleigh LaFrance - Project Architect



01.30.2026

Name - Title

Signature

Date